



Salt Spray Test Certificate

Page 1 of 1

Stephen Loyd
Precision Wall Systems, Inc.
1821 Levee Street
Dallas, TX 75207

Date Issued : 06/17/2010
Lab Number : L10081683
PO Number : 7087
Location of Test: AADFW Lab
Date Tested : 06/17/2010
File Number : 0001923-00

PH: (214) 774-4502

FX: (214) 432-5963

Revision Date :

Rev: 00

*Red corrosion was noted on the stone samples. More on the natural stone than the Arriscraft. This corrosion appeared in the first 24 Hours and did not grow. The only effect it had on the aluminum was staining.

Exposure Time: 1008 hoursPhotograph(s): N/AProcess Specification(s):

Spec: N/A, Report Only

<u>Test Method</u>	<u>Rev</u>
ASTM B 117	-09

Equipment:
Singleton - SN: SCCH22-8528

Support Method:
Plastic Rack

Cleaning Method:
Running Water

Part #: N/S

Description: Samples


Results:

(Military Time)

<u>Sample</u>	<u>[Date In</u>	<u>Time In]</u>	<u>[Date Out/Time Out]</u>	<u>Results</u>	<u>Status</u>
1-3 No Blocks	05/06/2010	09:00	06/17/2010 09:00	No Corrosion on significant areas	N/A
1-3 Natural Limes	05/06/2010	09:00	06/17/2010 09:00	No Corrosion on significant areas	N/A
1-3 Arriscraft cals	05/06/2010	09:00	06/17/2010 09:00	No Corrosion on significant areas*	N/A

Disposition: For Review Only, based only on the test data reported above. I certify that these are accurate and true results of the indicated tests performed in accordance with the AADFW QA Manual and AADFW test Procedures. A2LA Accreditation Certificate #603.01 in the Mechanical Field of Testing.

AADFW, Inc.


 Jeremy Wilson, B.S., E.I. T., Metallurgist